



MRC 2025 Fire

Incident Update

CCH Next Steps

Incident Investigation

PBF Root Cause Analysis (RCA) received
06/30/25

CCH 3rd Party Investigation Complete Draft Report issued. 45-Day public Notice period.

Safety Inspection

CCH Team completed
3/21/25

Continued oversight by CCH team until start up

Long Term Health Impacts

Public Meeting 6/17/25. 45-Day public notice period

CCH will continue to receive direction at ISO/CWS meetings

Full Facility Audit

CCH will work with a 3rd Party Consultant

The audit is targeted to be completed in late summer 2025

Marathon 2023 Fire

Incident Update



Statistics



● TOTAL RECOMMENDATIONS # 8
● OPEN RECOMMENDATIONS # 8
● CLOSED RECOMMENDATIONS # 0

0% 100 vs 0
TOTAL % OPEN VS. CLOSED

**No recommendations were made to Contra Costa County*



American Petroleum Institute (API)

- Revise API RP 556 *Instrumentation, Control, and Protective Systems for Gas Fired Heaters*



Martinez Renewable Fuels

Marathon Martinez Renewables

- Implement engineering safeguards to detect and prevent afterburning
- Implement tube metal temperature alarming consistent with corporate guidance
- Implement changes to improve Walk the Line performance
- Complete a comprehensive gap assessment of the Martinez facility against Marathon Corporate policies



Marathon Petroleum Corporation

- Update corporate "Process Heater Not-to-Exceed (NTE) Limits and Alarms" standard
- Update the corporate "Heater Application Standard"
- Confirm the results of the Martinez facility's comprehensive gap assessment required. Upon completion, conduct an Operations Excellence full assessment on the Martinez facility.