ORDINANCE NO. 2025-19

ADOPTION OF CALIFORNIA BUILDING STANDARDS CODES

The Contra Costa County Board of Supervisors ordains as follows (omitting the parenthetical footnotes from the official text of the enacted or amended provisions of the County Ordinance Code):

SECTION I. SUMMARY. This ordinance adopts the 2025 California Building Code, the 2025 California Residential Code, the 2025 California Electrical Code, the 2025 California Mechanical Code, the 2025 California Plumbing Code, the 2025 California Energy Code, the 2025 California Historical Building Code, the 2025 California Existing Building Code, and the 2025 California Green Building Standards Code, with changes, additions, and deletions that are necessary because of local climatic, geological, or topographical conditions. This ordinance is adopted pursuant to Health and Safety Code sections 17922, 17958, 17958.5, and 17958.7, and Government Code sections 50020 through 50022.10.

SECTION II. Section 74-2.002 (Adoption) of Division 74 (Building Code) of the County Ordinance Code is amended to read:

74-2.002 Adoption.

- (a) The building code of this county is the 2025 California Building Code (California Code of Regulations, Title 24, Part 2, Volumes 1 and 2), the 2025 California Residential Code (California Code of Regulations, Title 24, Part 2.5), the 2025 California Energy Code (California Code of Regulations, Title 24, Part 6), the 2025 California Historical Building Code (California Code of Regulations, Title 24, Part 8), the 2025 California Existing Building Code (California Code of Regulations, Title 24, Part 10), and the 2025 California Green Building Standards Code (California Code of Regulations, Title 24, Part 11), as amended by the changes, additions, and deletions set forth in this division and Division 72.
- (b) The 2025 California Building Code, with the changes, additions, and deletions set forth in Chapter 74-4 and Division 72, is adopted by this reference as though fully set forth in this division.
- (c) The 2025 California Residential Code, with the changes, additions, and deletions set forth in Chapter 74-4 and Division 72, is adopted by this reference as though fully set forth in this division.
- (d) The 2025 California Energy Code, with the changes, additions, and deletions set forth in Chapter 74-4 and Division 72, is adopted by this reference as though fully set forth in this division.

- (e) The 2025 California Historical Building Code, with the changes, additions, and deletions set forth in Chapter 74-4 and Division 72, is adopted by this reference as though fully set forth in this division.
- (f) The 2025 California Existing Building Code, with the changes, additions, and deletions set forth in Chapter 74-4 and Division 72, is adopted by this reference as though fully set forth in this division
- (g) The 2025 California Green Building Standards Code, with the changes, additions, and deletions set forth in Chapter 74-4 and Division 72, is adopted by this reference as though fully set forth in this division.
- (h) At least one copy of this building code is now on file with the building inspection division, and the other requirements of Government Code section 50022.6 have been and shall be complied with.
- (i) As of the effective date of the ordinance from which this division is derived, the provisions of the building code are controlling and enforceable within the county. (Ords. 2025-19, § 2, 2022-35 § 2, 2022-02 § 2, 2019-31 § 2, 2016-22 § 2, 2013-24 § 2, 2011-03 § 2, 2007-54 § 3, 2002-31 § 3, 99-17 § 5, 99-1, 90-100 § 5, 87-55 § 4, 80-14 § 5, 74-30.)

SECTION III. Chapter 74-4 (Modifications) of Division 74 (Building Code) of the County Ordinance Code is amended to read:

Chapter 74-4 MODIFICATIONS

74-4.002 Amendments to CBC. The 2025 California Building Code ("CBC") is amended by the changes, additions, and deletions set forth in this chapter and Division 72. Section numbers used in this section are those of the 2025 California Building Code.

- (a) CBC Chapter 1 (Administration) is amended by the provisions of Division 72 of this code and as follows:
 - (1) Sections 103 and 113 of CBC Chapter 1 are deleted.
 - (2) In Section 105.2 (Work exempt from permit) of CBC Chapter 1 (Administration), subsection 4, is amended to read:
 - 4. Retaining walls that are not more than 3 feet in height measured from the top of the footing to the top of the wall and that have a downward ground slope at the bottom of the retaining wall not exceeding 1(vertical):10(horizontal), unless supporting a surcharge or ground slope exceeding 1(vertical):2(horizontal) or impounding Class I, II, or III-a liquids.

(3) Section 107.2.1 (Information on Construction Documents) of CBC Chapter 1 (Administration) is amended to read:

107.2.1 Information on Construction Documents. Construction documents shall include dimensions and shall be drawn to scale on suitable material. Electronic media documents may be submitted when approved in advance by the building official. Construction documents shall be of sufficient clarity to indicate the location, nature, and extent of the work proposed and to show in detail that it will conform to this code and all relevant laws, ordinances, rules, and regulations. The first sheet of each set of plans shall include contact information for the owner and the person or persons who prepared the plans. Plans shall include a plot plan showing all existing property lines labeled and fully dimensioned, the elevations of the top and toe of cuts and fills, and the location of the proposed building with distances to all property lines and to every existing building on the property. Instead of detailed specifications, the county building official may approve references on the plans to a specific section or part of this code or other ordinances or laws.

(4) Section 110.1 (Inspections - General) of CBC Chapter 1 (Administration) is amended by adding the following to the end of that section:

At the time of first inspection by the county building official, a California licensed Land Surveyor or Civil Engineer shall certify in writing that the structure is placed according to the approved set of plans. The written certification must include the site address and permit number. This requirement does not apply to alterations or repairs to existing structures that do not affect the exterior limits of the existing structures.

(b) Section 907.2.11.2.5.1 is added to Section 907.2.11.2.5 (Existing Group R occupancies) of CBC Chapter 9 (Fire Protection and Life Safety Systems), to read:

907.2.11.2.5.1 Existing flat roof buildings. In existing flat roof buildings, the installation of a smoke detector that complies with California Residential Code Section R310.6 shall be required when a pitched roof is added on top of the existing flat roof and the solid sheathing of the flat roof is not removed.

(c) Section 1405.2 is added to Section 1405 (Combustible materials on the exterior side of exterior walls) of CBC Chapter 14 (Exterior Walls), to read:

1405.2 Wood shakes or shingles. Wood shakes or shingles used for exterior wall covering shall be fire treated.

///

- (d) In Section 1705.3 (Concrete construction) of CBC Chapter 17 (Special Inspections and Tests), Exception 1 is amended to read:
 - 1. Isolated spread concrete footings of buildings three stories or less above grade plane that are fully supported on earth or rock, where the structural design of the footing is based on a specified compressive strength of no greater than 2,500 pounds-per-square inch (psi) (17.2 MPa).
- (e) Section 1809.8 (Plain concrete footings) of CBC Chapter 18 (Soils and Foundations) is deleted.
- (f) Section 1810.3.9.3 (Placement of reinforcement) of CBC Chapter 18 (Soils and Foundations) is amended by deleting Exception 3.
- (g) Section 1905.6.2 (Seismic design categories C, D, E, and F) of CBC Chapter 19 (Concrete) is amended to read:

1905.6.2 Seismic design categories C, D, E, and F. Structures assigned to Seismic Design Category C, D, E, or F shall not have elements of structural plain concrete, except as follows:

- 1. Reserved.
- 2. Isolated footings of plain concrete supporting pedestals or columns are permitted, provided the projection of the footing beyond the face of the supported member does not exceed the footing thickness.
- 3. Reserved.
- (h) Section 1906 (Footings for light-frame construction) of CBC Chapter 19 (Concrete) is deleted.
- (i) Section 1907.5 (Minimum Slab Provisions General) is added to Section 1907 (Slabs-On-Ground) of CBC Chapter 19 (Concrete), to read:

Section 1907.5 Minimum Slab Provisions – General. Slabs shall have a minimum reinforcement of 6-inch by 6-inch, 10-gauge wire mesh or equal at midheight of the slab.

(j) Appendix C, Appendix I, and Appendix P of the CBC are incorporated into the County building code. (Ords. 2025-19 § 3, 2022-35 § 3, 2019-31 § 3, 2016-22 § 3, 2013- 24 § 3, 2011-03 § 3, 2007-54 § 4, 2002-31 § 3, 99- 17 § 6, 99-1, 90-100 § 6, 87-55 § 5, 80-14 § 6, 74-30 § 1.)

74-4.004 Amendments to CRC. The 2025 California Residential Code ("CRC") is amended by the changes, additions, and deletions set forth in this chapter and Division 72. Section numbers used in this section are those of the 2025 California Residential Code.

- (a) CRC Chapter 1 (Administration) is amended by the provisions of Division 72 of this code and as follows:
 - (1) Sections R103 and R112 of CRC Chapter 1 are deleted.
 - (2) In Section R105.2 (Work exempt from permit) of CRC Chapter 1 (Administration), subsection 3 is amended to read:
 - 3. Retaining walls that are not more than 3 feet in height measured from the top of the footing to the top of the wall and that have a downward ground slope at the bottom of the retaining wall not exceeding 1(vertical):10(horizontal), unless supporting a surcharge or ground slope exceeding 1(vertical):2(horizontal) or impounding Class I, II, or III-a liquids.
 - (3) Section R106.1.1 (Information on Construction Documents) of CRC Chapter 1 (Administration) is amended to read:
 - 106.1.1 Information on Construction Documents. Construction documents shall include dimensions and shall be drawn to scale on suitable material. Electronic media documents may be submitted when approved in advance by the building official. Construction documents shall be of sufficient clarity to indicate the location, nature, and extent of the work proposed and to show in detail that it will conform to this code and all relevant laws, ordinances, rules, and regulations. The first sheet of each set of plans shall include contact information for the owner and the person or persons who prepared the plans. Plans shall include a plot plan showing all existing property lines labeled and fully dimensioned, the elevations of the top and toe of cuts and fills, and the location of the proposed building with distances to all property lines and to every existing building on the property. Instead of detailed specifications, the county building official may approve references on the plans to a specific section or part of this code or other ordinances or laws.
 - (4) Section R109.1.1 (Foundation inspection) of CRC Chapter 1 (Administration) is amended by adding the following to the end of that section:

At the time of first inspection by the county building official, a California licensed Land Surveyor or Civil Engineer shall certify in writing that the structure is placed according to the approved set of plans. The written certification must include the site address and permit number. This

requirement does not apply to alterations or repairs to existing structures that do not affect the exterior limits of the existing structures.

(b) Section R310.8.1.1 is added to Section R310.8 (Existing Group R-3 occupancies) of CRC Chapter 3 (Building Planning), to read:

R310.8.1.1 Existing flat roof buildings. In existing flat roof buildings, the installation of a smoke detector that complies with Section R310.6 shall be required when a pitched roof is added on top of the existing flat roof and the solid sheathing of the flat roof is not removed.

- (c) Section R602.10.3(3) (Bracing Requirements Based on Seismic Design Category) of CRC Chapter 6 (Wall Construction) is amended as follows:
 - (1) The title of Table R602.10.3(3) is amended to read:

TABLE R602.10.3(3)i

- (2) Footnote "i" is added to Table R602.10.3(3), to read:
 - i. Method GB is not permitted and the use of Method PCP is limited to one-story dwellings and accessory structures.
- (d) Section R602.10.4.5 (Limits on methods GP and PCP) is added to Section R602.10.4 (Construction methods for braced wall panels) of CRC Chapter 6 (Wall Construction), to read:

R602.10.4.5 Limits on methods GB and PCP. Method GB is not permitted, but gypsum board is permitted to be installed on the opposite side of the studs from other types of braced wall panel sheathing. The use of Method PCP is limited to one-story dwellings and accessory structures.

(e) Appendix BB, Appendix BF, Appendix BJ, and Appendix CI of the CRC are incorporated into the County building code. (Ords. 2025-19 § 3, 2022-35 § 3, 2019-31 § 3, 2016-22 § 3, 2013- 24 § 3, 2011-03 § 3.)

74-4.006 Amendments to CGBSC. The 2025 California Green Building Standards Code ("CGBSC") is amended by the changes, additions, and deletions set forth in this chapter and Division 72. Section numbers used in this section are those of the 2025 California Green Building Standards Code.

(a) Section 301.1.1 (Additions and alterations) of CGBSC Chapter 3 (Green Building) is amended by adding the following to the end of that section:

The mandatory provisions of Section 4.408 shall apply to the following types of construction or demolition projects for existing residential buildings:

- 1. Projects that increase the total combined conditioned and unconditioned building area by 5,000 square feet or more.
- 2. Alterations to existing structures impacting 5,000 square feet or more of total combined conditioned and unconditioned building area.
- 3. Demolition projects when a demolition permit is required.

Exception: Demolition projects undertaken because the enforcing agency has determined that the demolition is necessary to abate a public nuisance or otherwise protect public health and safety.

For the purposes of determining whether a project meets the 5,000 square-foot threshold, the enforcing agency may deem all phases of a project and all related projects taking place on a single parcel, or on two or more adjoining parcel(s), as a single project.

(b) Section 301.3.2 (Waste diversion) of CGBSC Chapter 3 (Green Building) is amended to read:

Section 301.3.2 Waste diversion. The requirements of Section 5.408 shall be required for additions, alterations, and demolition whenever a permit is required for work.

Exception: Demolition projects undertaken because the enforcing agency has determined that the demolition is necessary to abate a public nuisance or otherwise protect public health and safety.

- (c) Section 4.106.4.2.2 (Multifamily Dwellings) of CGBSC Chapter 4 (Residential Mandatory Measures) is amended by adding subsection (2)(d) to the end of that section, to read:
 - d. **EV Chargers.** Notwithstanding anything in this section to the contrary, at least ten (10) percent of the total number of parking spaces shall be equipped with fully-operational Level 2 EVSE.

///

///

///

(d) Section 4.408.1 (Construction waste management) of CGBSC Chapter 4 (Residential Mandatory Measures) is amended to read:

Section 4.408.1 Construction waste management. Recycle and/or salvage for reuse a minimum of 65 percent of the nonhazardous construction and demolition waste in accordance with Section 4.408.2.

Exceptions:

- 1. Excavated soil and land-clearing debris.
- 2. The enforcing agency may identify alternate waste reduction requirements if the agency determines that an owner or contractor has adequately demonstrated that diversion facilities necessary for the owner to comply with this section do not exist or are not located within a reasonable distance from the jobsite.
- (e) Section 4.408.2 (Construction waste management plan) of CGBSC Chapter 4 (Residential Mandatory Measures) is amended to read:

Section 4.408.2 Construction waste management plan. Submit a construction waste management plan for the project in conformance with Items 1 through 5 prior to issuance of a building permit. The construction waste management plan shall be updated as necessary, subject to approval by the enforcing agency. The approved plan, and any updates, shall be available during construction for examination by the enforcing agency. The plan must do all of the following:

- 1. Identify the construction and demolition waste materials to be diverted from disposal by recycling, reuse on the project, or salvage for future use or sale.
- 2. Specify if construction and demolition waste materials will be sorted on-site (source-separated) or bulk mixed (single stream).
- 3. Identify diversion and disposal facilities where the construction and demolition waste material will be taken and identify the waste management companies, if any, that will be utilized to haul the construction and demolition waste material. A waste management company utilized to haul construction and demolition waste material must have all applicable County approvals.
- 4. Identify construction methods employed to reduce the amount of construction and demolition waste generated.
- 5. Specify that the amount of construction and demolition debris shall be calculated consistent with the enforcing agency's requirements

for the weighing of debris. The owner shall ensure that all construction and demolition debris diverted or disposed are measured and recorded by weight or volume using the most accurate method of measurement available. To the extent practicable, all construction and demolition debris shall be weighed using scales. Scales shall be in compliance with all regulatory requirements for accuracy and maintenance. For construction and demolition debris for which weighing is not possible due to lack of scales, or not practical due to materials being reused on-site or elsewhere, or not practical due to other considerations, and upon approval by the enforcing agency, a volumetric measurement shall be used. The owner shall convert volumetric measurements to weight using the standardized conversion factors approved by the enforcing agency for this purpose.

- (f) Section 4.408.3 (Waste management company) of CGBSC Chapter 4 (Residential Mandatory Measures) is deleted.
- (g) Section 4.408.5 (Documentation) of CGBSC Chapter 4 (Residential Mandatory Measures) is amended to read:

Section 4.408.5 Documentation. A construction waste management final report containing information and supporting documentation that demonstrates compliance with Section 4.408.1, Section 4.408.2, Items 1 through 5, and, when applicable, Section 4.408.4 or Section 4.408.4.1, shall be provided to the enforcing agency before the final inspection. The required documentation shall include, but is not necessarily limited to, the following:

- 1. Documentation of the quantity, by weight, of each material type diverted or disposed, consistent with the requirements of Section 4.408.2, Item 5, and receipts or written certification from all receiving facilities utilized to divert or dispose of waste generated by the project that substantiate the amounts specified on the construction waste management final report; or
- 2. For projects that satisfy the waste stream reduction alternative specified in Section 4.408.4 or Section 4.408.4.1, documentation of the quantity, by weight, of each material type disposed of and the total combined weight of construction and demolition waste disposed in landfills as a result of the project, the corresponding pounds disposed per square foot of the building area, and receipts or written certification from all receiving facilities utilized to dispose waste generated by the project that substantiate the amounts specified on the construction waste management final report.

(h) Table 5.106.5.3.1 (EV Capable Spaces and EVCS) of CGBSC Chapter 5 (Nonresidential Mandatory Measures) is amended to read:

TABLE 5.106.5.3.1 – EV CAPABLE SPACES AND EVCS

TOTAL NUMBER	NUMBER OF	OTHER THAN	OFFICE AND
OF ACTUAL	REQUIRED EV	OFFICE AND	RETAIL
PARKING SPACES	CAPABLE SPACES	RETAIL NUMBER	NUMBER OF
		OF REQUIRED	REQUIRED
		$EVCS^{2,3}$	$EVCS^{2,3}$
1-9	0	0	0
10-25	4	3	3
26-50	8	5	6
51-75	13	8	8
76-100	17	10	13
101-150	25	15	19
151-200	35	20	26
201 and over	20 percent of actual	50 percent of EV	75 percent of
	parking spaces ¹	capable spaces ¹	EV capable
			spaces ¹

- 1. Calculation for spaces shall be rounded up to the nearest whole number.
- 2. Each EVCS shall reduce the number of required EV capable spaces by the same number.
- 3. At least one Level 2 EVSE shall be provided.
- (i) Section 5.408.1 (Construction waste management) of CGBSC Chapter 5 Nonresidential Mandatory Measures) is amended to read:

Section 5.408.1 Construction waste management. Recycle and/or salvage for reuse a minimum of 65 percent of the nonhazardous construction and demolition waste in accordance with Section 5.408.1.1.

Exceptions:

- 1. Excavated soil and land-clearing debris.
- 2. The enforcing agency may identify alternate waste reduction requirements if the agency determines that an owner or contractor has adequately demonstrated that diversion facilities necessary for the owner to comply with this section do not exist.
- (j) Section 5.408.1.1 (Construction waste management plan) of CGBSC Chapter 5 Nonresidential Mandatory Measures) is amended to read:

Section 5.408.1.1 Construction waste management plan. Submit a construction waste management plan for the project in conformance with Items 1 through 5 prior to issuance of a building permit. The construction waste

management plan shall be updated as necessary, subject to approval by the enforcing agency. The approved plan, and any updates, shall be available during construction for examination by the enforcing agency. The plan must do all of the following:

- 1. Identify the construction and demolition waste materials to be diverted from disposal by recycling, reuse on the project, or salvage for future use or sale.
- 2. Specify if construction and demolition waste materials will be sorted on-site (source-separated) or bulk mixed (single stream).
- 3. Identify diversion and disposal facilities where the construction and demolition waste material will be taken and identify the waste management companies, if any, that will be utilized to haul the construction and demolition waste material. A waste management company utilized to haul construction and demolition waste material must have all applicable County approvals.
- 4. Identify construction methods employed to reduce the amount of construction and demolition waste generated.
- 5. Specify that the amount of construction and demolition debris shall be calculated consistent with the enforcing agency's requirements for the weighing of debris. The owner shall ensure that all construction and demolition debris diverted or disposed are measured and recorded by weight or volume using the most accurate method of measurement available. To the extent practicable, all construction and demolition debris shall be weighed using scales. Scales shall be in compliance with all regulatory requirements for accuracy and maintenance. For construction and demolition debris for which weighing is not possible due to lack of scales, or not practical due to materials being reused on-site or elsewhere, or not practical due to other considerations, and upon approval by the enforcing agency, a volumetric measurement shall be used. The owner shall convert volumetric measurements to weight using the standardized conversion factors approved by the enforcing agency for this purpose.
- (k) Section 5.408.1.2 (Waste management company) of CGBSC Chapter 5 (Nonresidential Mandatory Measures) is deleted.

///

- (1) Section 5.408.1.4 (Documentation) of CGBSC Chapter 5 (Nonresidential Mandatory Measures) is amended to read:
 - **Section 5.408.1.4 Documentation.** A construction waste management final report containing information and supporting documentation that demonstrates compliance with Section 5.408.1, Section 5.408.1.1, Items 1 through 5, and, when applicable, Section 5.408.1.3, shall be provided to the enforcing agency before the final inspection. The required documentation shall include, but may not necessarily be limited to, the following:
 - 1. Documentation of the quantity, by weight, of each material type diverted or disposed, consistent with the requirements of Section 5.408.1.1, Item 5, and receipts or written certification from all receiving facilities utilized to divert or dispose of waste generated by the project that substantiate the amounts specified on the construction waste management final report; or
 - 2. For projects that satisfy the waste stream reduction alternative specified in Section 5.408.1.3, documentation of the quantity, by weight, of each new construction material type disposed and the total combined weight of new construction waste disposed as a result of the project, the corresponding pounds of new construction disposal per square foot of the building area, and receipts or written certification from all receiving facilities utilized to dispose of waste generated by the project that substantiate the amounts specified on the construction waste management final report.

(Ords. 2025-19 § 3, 2022-35 § 3, 2019-31 § 3, 2016-22 § 3, 2015-22 § 2.)

74-4.008 Amendments to CEBC. The 2025 California Existing Building Code ("CEBC") is amended by the changes, additions, and deletions set forth in this chapter and Division 72. Section numbers used in this section are those of the 2025 California Existing Building Code

- (a) CEBC Chapter 1 (Scope and Administration) is amended by the provisions of Division 72 of this code and as follows:
 - (1) Sections 103 and 112 of CEBC Chapter 1 (Scope and Administration) are deleted.
 - (2) Section 106.1 (Construction Documents General) of CEBC Chapter 1 (Scope and Administration) is amended by deleting the exception.
 - (3) Section 106.2.1 (Construction documents) of CEBC Chapter 1 (Scope and Administration) is amended to read:
 - **106.2.1 Construction documents.** Construction documents shall include dimensions and shall be drawn to scale on suitable material. Electronic

media documents may be submitted when approved in advance by the building official. Construction documents shall be of sufficient clarity to indicate the location, nature, and extent of the work proposed and to show in detail that it will conform to this code and all applicable laws, ordinances, rules, and regulations. The first sheet of each set of plans shall include contact information for the owner and for the person or persons who prepared the plans. Plans shall include a plot plan showing all existing property lines labeled and fully dimensioned, the elevations of the tops and toes of cuts and fills, and the location of the proposed building with distances to all property lines and to every existing building on the property. Instead of detailed specifications, the county building official may approve references on the plans to a specific section or part of this code or other ordinances or laws.

(Ords. 2025-19 § 3, 2022-35 § 3, 2019-31 § 3, 2016-22 § 3.)

74-4.010 Reserved.

(Ords. 2025-19 § 3, 2022-35 § 3, 2022-02 § 3.)

SECTION IV. Section 76-2.002 (Adoption) of Division 76 (Electrical Code) of the County Ordinance Code is amended to read:

76-2.002 Adoption.

- (a) The electrical code of this county is the 2025 California Electrical Code (California Code of Regulations, Title 24, Part 3) ("CEC"), as amended by the changes, additions, and deletions set forth in this division and Division 72.
- (b) The 2025 California Electrical Code, with the changes, additions, and deletions set forth in Chapter 76-4 and Division 72, is adopted by this reference as though fully set forth in this division.
- (c) At least one copy of this electrical code is now on file with the building inspection division, and the other requirements of Government Code section 50022.6 have been and shall be complied with.
- (d) As of the effective date of the ordinance from which this division is derived, the provisions of the electrical code are controlling and enforceable within the county. (Ords. 2025-19 § 4, 2022-35 § 4, 2019-31 § 4, 2016-22 § 4, 2013-24 § 4, 2011-03 § 4, 2007-54 § 5, 2002-31 § 4, 99-17 § 11, 89-60 § 2, 82-23 § 2, 79-67, 76-24.)

///

SECTION V. Section 78-2.002 (Adoption) of Division 78 (Plumbing Code) of the County Ordinance Code is amended to read:

78-2.002 Adoption.

- (a) The plumbing code of this county is the 2025 California Plumbing Code (California Code of Regulations, Title 24, Part 5), as amended by the changes, additions, and deletions set forth in Division 72.
- (b) The 2025 California Plumbing Code, with the changes, additions, and deletions set forth in Division 72, is adopted by this reference as though fully set forth in this division.
- (c) At least one copy of this plumbing code is now on file with the building inspection division, and the other requirements of Government Code section 50022.6 have been and shall be complied with.
- (d) As of the effective date of the ordinance from which this division is derived, the provisions of the plumbing code are controlling and enforceable within the county. (Ords. 2025-19 § 5, 2022-35 § 5, 2019-31 § 5, 2016-22 § 6, 2013-24 § 5, 2011-03 § 5, 2007-54 § 6, 2002-31 § 5, 99-17 § 12, 74-29.)

SECTION VI. Section 710-2.002 (Adoption) of Division 710 (Mechanical Code) of the County Ordinance Code is amended to read:

710-2.002 Adoption.

- (a) The mechanical code of this county is the 2025 California Mechanical Code (California Code of Regulations, Title 24, Part 4), as amended by the changes, additions, and deletions set forth in Division 72.
- (b) The 2025 California Mechanical Code, with the changes, additions, and deletions set forth in Division 72, is adopted by this reference as though fully set forth in this division.
- (c) At least one copy of this mechanical code is now on file with the building inspection division, and the other requirements of Government Code section 50022.6 have been and shall be complied with.
- (d) As of the effective date of the ordinance from which this division is derived, the provisions of the mechanical code are controlling and enforceable within the county. (Ords. 2025-19 § 6, 2022-35 § 6, 2019-31 § 6, 2016-22 § 7, 2013-24 § 6, 2011-03 § 6, 2007-54 § 7, 2002-31 § 6, 99-17 § 13, 88-91 § 5, 74-31.)

///

SECTION VII. Section 72-6.212 of the County Ordinance Code is amended to read:

72-6.212 Expiration of permit.

- (a) A permit issued by the county building official becomes void if either of the following occur:
 - (1) The work authorized by the permit is not commenced within 12 months after the permit issuance date. Evidence that work has commenced consists of at least one approved inspection.
 - (2) The work authorized by the permit is suspended or abandoned for a period of 12 consecutive months after the work is commenced. Work is deemed suspended or abandoned for a period of 12 consecutive months if no approved inspection occurs during that time.
- (b) A permittee holding an unexpired permit may apply to the county building official for a permit extension. Upon written request by the permittee demonstrating justifiable cause for the delay, the county building official may grant one or more extensions of time for additional periods not exceeding 180 days per each extension.
- (c) Once a permit becomes void, a new permit must be obtained before any work is commenced or recommenced, and a new permit fee must be paid. (Ords. 2025-19 § 7, 2022-35 § 7, 2019-31 § 7, 2007-54 § 2, 2002-31 § 2, 99-1 § 5, 87-55 § 3, 80-14 § 3, 74-32 § 2, 71-32 § 1, 67-70 § 3: prior code § 7106: Ord. 1372 § 5H).

SECTION VIII. VALIDITY. The Contra Costa County Board of Supervisors declares that if any section, paragraph, sentence, or word of this ordinance or of the 2025 California Building Code, Residential Code, Electrical Code, Mechanical Code, Plumbing Code, Energy Code, Historical Building Code, Existing Building Code, or Green Building Code, as adopted and amended herein, is declared for any reason to be invalid by a court, it is the intent of the Contra Costa County Board of Supervisors that it would have passed all other portions or provisions of this ordinance independent of the elimination herefrom of any portion or provision as may be declared invalid by a court.

///	
///	
///	
///	
///	
///	

SECTION IX. EFFECTIVE AND OPERATIVE DATES. This ordinance becomes effective 30 days after passage. This ordinance becomes operative January 1, 2026, or 30 days after passage, whichever is later. Within 15 days of passage, this ordinance shall be published once in the East Bay Times, a newspaper published in this County. This ordinance shall be published in a manner satisfying the requirements of Government Code section 25124, with the names of supervisors voting for and against it.

PASSED on _	, by the following vote:		
AYES: NOES: ABSENT: ABSTAIN:			
ATTEST:	MONICA NINO, Clerk of the Board of Supervisors and County Administrator	Board Chair	
By:	Deputy	[SEAL]	